



TVF  
DOC\_0001571-0

EG-försäkran om överensstämmelse  
EC Declaration of conformity  
EG-Konformitätserklärung / Déclaration CE de conformité  
Deklaracja zgodności

Försäkrar under eget ansvar att produkten,  
Declare under our sole responsibility that the product,

NIBE™ ERS 10-400  
NIBE™ ERS 20-250

Erklären in alleiniger Verantworthen, daß das Produkt,  
Déclare sous sa seule responsabilité que le produit,  
Deklarujemy przyjmując wyłączną odpowiedzialność, że produkt  
Ventilation heat exchanger  
Ventilation heat exchanger

som omfattas av denna försäkran är i överensstämmelse med följande direktiv  
to which this declaration relates is in conformity with requirements of the following directives  
auf das sich diese Erklärung bezieht, konform ist mit den Anforderung der Richtlinien  
auxquels la présente déclaration s'applique, sont conformes aux exigences des directives suivantes  
do którego niniejsza deklaracja się odnosi, wyprodukowano zgodnie z wymogami następujących dyrektyw

EC directive on:

Electromagnetic Compatibility (EMC): 2014/30/EU

Low Voltage Directive (LVD): 2014/35/EU

Restriction of the use of Hazardous Substances (RoHS II): 2011/65/EU

Eco-design requirements for energy-related products: 2009/125/EC

Implementing Directive 2009/125/EC requirements for ventilation units Text with EEA relevance EC No 1253/2014

Överensstämmelsen är kontrollerad i enlighet med följande EN-standarder  
The conformity was checked in accordance with the following EN-standards  
Die Konformität wurde überprüft anhand der EN-Normen  
Cette conformité été vérifiée selon les normes suivantes  
Zgodność została sprawdzona z wymaganiami następujących norm

EN 60 335-1:2012, A11:2014, A12:2017  
EN 60 335-2-40:2003, A1:2006, A2:2009, A11:2004,  
A12:2005, A13:2013  
EN 61 000-6-1:2007

EN 61 000-6-3:2007, A1:2011

EN 308:1997

EN 13 141-7:2010

EN ISO 3741:2010

Safety of household appliances ...  
... for electrical heat pumps,

Immunity for residential, commercial and  
light-industrial environments

Emission standard for residential, commercial  
and light-industrial environments

Test procedures for establishing performance  
of air to air and flue gases heat recovery  
devices

Performance testing of a mechanical supply  
and exhaust ventilation units for mechanical  
ventilation systems intended for single  
family dwellings

Determination of sound power levels and sound  
energy levels of noise sources using sound  
pressure

Markaryd 2019-01-03

Kenneth Magnusson  
Quality & Environmental Manager

Mattias Nilsson  
Product Development Manager